

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6070729

Douglas ESD
 1871 NE Stephens
 Roseburg, OR 97470

Project: General

Date Reported: 07/19/16
 Date Received: 07/07/16 16:00
 Sampled By: Terry Shipman

Client Contact: Jack Musser

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6070729-01	Sample Location: Douglas Rm									
	Lead	1030	0.011	mg/L	0.002	0.02	07/07/16 06:40	07/11/16	DJP	
	Copper		0.105	mg/L	0.010	1.3	07/07/16 06:40	07/11/16	DJP	
6070729-02	Sample Location: Hallway Fountain									
	Lead	1030	0.017	mg/L	0.002	0.02	07/07/16 06:42	07/11/16	DJP	
	Copper		0.420	mg/L	0.010	1.3	07/07/16 06:42	07/11/16	DJP	
6070729-03	Sample Location: Mop Closet									
	Lead	1030	0.007	mg/L	0.002	0.02	07/07/16 06:45	07/11/16	DJP	
	Copper		0.055	mg/L	0.010	1.3	07/07/16 06:45	07/11/16	DJP	
6070729-04	Sample Location: Upstairs Kitchen									
	Lead	1030	0.007	mg/L	0.002	0.02	07/07/16 06:47	07/11/16	DJP	
	Copper		0.060	mg/L	0.010	1.3	07/07/16 06:47	07/11/16	DJP	
6070729-05	Sample Location: Upstairs Bathroom									
	Lead	1030	0.083	mg/L	0.002	0.02	07/07/16 06:49	07/13/16	DJP	CON-1
	Copper		0.132	mg/L	0.010	1.3	07/07/16 06:49	07/13/16	DJP	
6070729-06	Sample Location: Print Shop									
	Lead	1030	ND	mg/L	0.002	0.02	07/07/16 06:51	07/11/16	DJP	
	Copper		0.016	mg/L	0.010	1.3	07/07/16 06:51	07/11/16	DJP	
6070729-07	Sample Location: Ladies Room 1st Sink									
	Lead	1030	ND	mg/L	0.002	0.02	07/07/16 06:52	07/11/16	DJP	
	Copper		0.074	mg/L	0.010	1.3	07/07/16 06:52	07/11/16	DJP	
6070729-08	Sample Location: Ladies Room 2nd Sink									
	Lead	1030	0.003	mg/L	0.002	0.02	07/07/16 06:53	07/11/16	DJP	
	Copper		0.097	mg/L	0.010	1.3	07/07/16 06:53	07/11/16	DJP	
6070729-09	Sample Location: Mens Room 1st Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6070729

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	07/07/16 06:54	07/11/16	DJP	
Copper			0.067	mg/L	0.010	1.3	07/07/16 06:54	07/11/16	DJP	
6070729-10	Sample Location: Mens Room 2nd Sink									
Lead		1030	0.014	mg/L	0.002	0.02	07/07/16 06:56	07/11/16	DJP	
Copper			0.097	mg/L	0.010	1.3	07/07/16 06:56	07/11/16	DJP	
6070729-11	Sample Location: Board Room									
Lead		1030	0.010	mg/L	0.002	0.02	07/07/16 06:58	07/11/16	DJP	
Copper			0.132	mg/L	0.010	1.3	07/07/16 06:58	07/11/16	DJP	
6070729-12	Sample Location: Restroom Back Entry									
Lead		1030	ND	mg/L	0.002	0.02	07/07/16 06:59	07/11/16	DJP	
Copper			0.025	mg/L	0.010	1.3	07/07/16 06:59	07/11/16	DJP	
6070729-13	Sample Location: Annex Reception Bathroom									
Lead		1030	ND	mg/L	0.002	0.02	07/07/16 07:30	07/11/16	DJP	
Copper			0.088	mg/L	0.010	1.3	07/07/16 07:30	07/11/16	DJP	
6070729-14	Sample Location: Annex Kitchenette									
Lead		1030	ND	mg/L	0.002	0.02	07/07/16 07:32	07/11/16	DJP	
Copper			0.074	mg/L	0.010	1.3	07/07/16 07:32	07/11/16	DJP	
6070729-15	Sample Location: Annex Classroom									
Lead		1030	ND	mg/L	0.002	0.02	07/07/16 07:34	07/11/16	DJP	
Copper			0.057	mg/L	0.010	1.3	07/07/16 07:34	07/11/16	DJP	
6070729-16	Sample Location: Annex Classroom Bathroom									
Lead		1030	ND	mg/L	0.002	0.02	07/07/16 07:36	07/11/16	DJP	
Copper			0.035	mg/L	0.010	1.3	07/07/16 07:36	07/11/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6070729

Qualifiers and Definitions


CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6072204

Douglas ESD 1871 NE Stephens Roseburg, OR 97470	Project: General Client Contact: Jack Musser	Date Reported: 08/18/16 Date Sampled: 07/21/16 13:00 Date Received: 07/22/16 17:00 Sampled By: Jack Musser
---	---	---

Sample Location: Upstairs Bathroom (Re-test Follow Up)

URC Sample #: 6072204-01

Matrix: Drinking Water


Metals


Analyte	Method	Code	Result	Units	MRL	MCL	Prepared	Analyzed	Analyst	Qualifier
Copper	EPA 200.8		0.011	mg/L	0.010	1.3	08/01/16	08/01/16	DJP	
Lead	EPA 200.8	1030	ND	mg/L	0.002	0.02	08/01/16	08/01/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.


 Ted Lunsford, Laboratory Supervisor



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6072204

Qualifiers and Definitions


DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.


Ted Lunsford, Laboratory Supervisor



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6072925

Douglas ESD
 1871 NE Stephens
 Roseburg, OR 97470

Project: General

Date Reported: 08/08/16
 Date Received: 07/28/16 17:00
 Sampled By: Jack Musser

Client Contact: Jack Musser

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6072925-01	Sample Location: W.C.Main #1									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 13:15	08/03/16	DJP	
Copper			0.281	mg/L	0.010	1.3	07/27/16 13:15	08/03/16	DJP	
6072925-02	Sample Location: W.C.Main #2									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 13:15	08/03/16	DJP	
Copper			0.341	mg/L	0.010	1.3	07/27/16 13:15	08/03/16	DJP	
6072925-03	Sample Location: W.C.Main #3									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 13:15	08/04/16	DJP	
Copper			0.160	mg/L	0.010	1.3	07/27/16 13:15	08/04/16	DJP	
6072925-04	Sample Location: W.C.Annex 1									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 13:05	08/04/16	DJP	
Copper			0.134	mg/L	0.010	1.3	07/27/16 13:05	08/04/16	DJP	
6072925-05	Sample Location: W.C.Annex 2									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 13:10	08/04/16	DJP	
Copper			0.433	mg/L	0.010	1.3	07/27/16 13:10	08/04/16	DJP	
6072925-06	Sample Location: W.C.Annex 3									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 13:00	08/04/16	DJP	
Copper			0.241	mg/L	0.010	1.3	07/27/16 13:00	08/04/16	DJP	
6072925-07	Sample Location: Phoenix EI Kitchen									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 14:45	08/04/16	DJP	
Copper			0.128	mg/L	0.010	1.3	07/27/16 14:45	08/04/16	DJP	
6072925-08	Sample Location: Stewart Classroom 1									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 14:10	08/04/16	DJP	
Copper			1.109	mg/L	0.010	1.3	07/27/16 14:10	08/04/16	DJP	
6072925-09	Sample Location: Stewart Classroom 2									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6072925

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 14:20	08/04/16	DJP	
Copper			0.642	mg/L	0.010	1.3	07/27/16 14:20	08/04/16	DJP	
6072925-10	Sample Location: Stewart Classroom 3									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 14:30	08/04/16	DJP	
Copper			0.384	mg/L	0.010	1.3	07/27/16 14:30	08/04/16	DJP	
6072925-11	Sample Location: Stewart Kitchen 1 (A)									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 14:15	08/04/16	DJP	
Copper			0.385	mg/L	0.010	1.3	07/27/16 14:15	08/04/16	DJP	
6072925-12	Sample Location: Stewart Kitchen 1 (B)									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 14:15	08/04/16	DJP	
Copper			0.367	mg/L	0.010	1.3	07/27/16 14:15	08/04/16	DJP	
6072925-13	Sample Location: Stewart Kitchen 2									
Lead		1030	ND	mg/L	0.002	0.02	07/27/16 14:20	08/04/16	DJP	
Copper			0.636	mg/L	0.010	1.3	07/27/16 14:20	08/04/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6072925

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager